

VOC Content Test Certificate

Monday 08th April 2024

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).
Product name: SPARTAN 2499 Pressure Sensitive Adhesive
Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	SPARTAN 2499 Pressure Sensitive Adhesive
General Purpose Adhesives and Sealants Limit: 50 grams per litre	13 grams per litre as VOC content per material
<i>We hereby certify SPARTAN 2499 Pressure Sensitive Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 08/04/2024

Expiry date: 28/02/2025

P24040034